

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRPWFC20174064, Public Works Infrastructure Permit - Commercial

COLEMAN EQUIPMENT

Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Subgrade Inspection	Steve Robbins	Passed	Monday, August 06, 2018

Informational

- 1 The parking lot and the commercial road has been tilled 9" and has had portlan cement tilled into the dirt. AS per our specs they are suppose to install 5-6 inches of Mo-type 5 over the subgrade. They got permission to just install the curbs and the asphalt over the subgrade. I spoke with Dan Harper about this and he said it was approved.

**Comments:**

---