

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181678, Building Permit - Residential

Address: 4430 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, August 07, 2018

Corrective Action Required

1 Misc

- Fire block notches at rim board in garage
STILL MISSING FIRESTOPPING AT LAUNDRY TO ATTIC

OKAY TO INSULATE

Comments: