

Temporary Certificate of Occupancy

Permit #: PRCOM20181348
Address: 699 NW BLUE PKWY, LEES SUMMIT, MO 64086
Inspected On: Wednesday, August 08, 2018
Inspected By: John Borns
Expiration Date: 8/16/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Wednesday, August 08, 2018

Corrective Action Required:

3	Misc	ICC A117.1 ACCESSIBLE WATER CLOSET DISTANCE FROM WALL: ALLOWABLE RANGE IS 16"-18".
---	------	---