

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161939, Building Permit - Commercial

Address: 825 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Commercial John Borns Failed Thursday, August 09, 2018

Partial Correction

1 Misc OK TO COVER WHEN READY FRAMING AND SYSTEMS TO BE ENCLOSED AT: ABOVE CEILING

Corrective Action Required

2 Misc **CHECK ALL SILL/SOLE PLATES: ENSURE EACH PIECE HAS MINIMUM OF TWO ANCHOR BOLTS; A.B. SPACING PER PRINTS; ONE A.B. WITHIN 12" OF EACH END OF EACH PIECE; WASHER + NUT TIGHTENED ON EACH BOLT**

Comments: