

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161941, Building Permit - Commercial

Address: 825 NW DONOVAN RD, Unit:G3, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Failed	Thursday, August 09, 2018

Partial Correction

1 Misc

OK TO COVER WHEN READY FRAMING AND SYSTEMS TO BE ENCLOSED AT: ABOVE CEILING

Corrective Action Required

2 Misc

CHECK ALL SILL/SOLE PLATES: ENSURE EACH PIECE HAS MINIMUM OF TWO ANCHOR BOLTS; A.B. SPACING PER PRINTS; ONE A.B. WITHIN 12" OF EACH END OF EACH PIECE; WASHER + NUT TIGHTENED ON EACH BOLT

Comments: