

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20182138, Building Permit - Residential

Address: 1853 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Thursday, August 09, 2018

Corrective Action Required

1 Misc

FIREBLOCK DROP CEILING IN BATHROOM

Corrective Action Required

2 Misc

- strap / plate bottom and top plate at plumbing sw left of egress
- Fire stop at bath sw wall and tub drain above
- Fire blocking at egress window is insufficient
- Protect plumbing at bath sink pen and vent
- Protect radon top and bottom
-

Comments: