

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20182242, Building Permit - Commercial

Address: 2600 SW WARD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Passed	Thursday, August 09, 2018
Rough Electrical Inspection - Commercial	Mark Harding	Passed	Thursday, August 09, 2018

Comments: OK TO COVER WHEN READY TRENCHED ELECTRICAL CONDUIT TO FEED SUB-PANEL IN NEW MODULAR BUILDING. NO ISSUES FOUND AT RACK-MOUNTED DISCONNECT NOR AT SUB-PANEL INSIDE MODULAR.