



**LEE'S SUMMIT**  
MISSOURI



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20181496	Date:	August 09, 2018
Project Title:	SAINT LUKES SURGICENTER -	Applicant:	
ALTERATIONS			
Location:		JOHNSON CONTROLS FIRE PROTECTION	
	120 NE SAINT LUKES BLVD, LEES	11019 Strange Line Road	
	SUMMIT, MO 64086	Lenexa, Kansas 66215	
Type of Work:		Primary: (913)894-0020	
Occupancy Group:	I-2		
Description:	ALTERATIONS TO EXISTING		
	SURGICENTER - INCLUDES		
	CONSTRUCTION OF NEW GI		
	PROCEDURE ROOM AND E		
	EXPANDING WAITING AREA		
Construction Type:	Type IA		
Map Page:	175X		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**1. Sequence of operations**

**ACTION REQUIRED:(veriiifed at testing)**

**Check the sequence of operations and confirm that all devices that actuate audible and visible evacuation signals are included to release magnetically held smoke doors.**

**2.ACTION REQUIRED: (information purposes)**

**Testing of all modifications done to the fire alarm system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300**

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**