

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20173755  
**Address:** 865 SW LEMANS LN, LEES SUMMIT, MO 64082  
**Inspected On:** Friday, August 10, 2018  
**Inspected By:** Khanh Nguyen Michael Weissenbach  
**Expiration Date:** 9/10/2018 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Temporary C of O	Friday, August 10, 2018

**Corrective Action Required:**

1	Misc	-INSTALL NO SMOKING SIGNAGE AT FRONT -INSTALL SIGNAGE FOR RESTROOM LOCATED ON LATCH SIDE -INSTALL WATER HEATER P/T DISCHARGE PIPING -15-20 AMP RECEPTACLES LOCATED IN KITCHEN AREA ARE REQUIRED TO BE GFCI -INSTALL MAXIMUM 15 AMP HACR BREAKER FOR THE WALK-IN REFRIGERATOR
---	------	--

**\*\*HEALTH, FIRE, WATER-APPROVED**

<b>Occupancy Inspection - Fire</b>	Michael Weissenbach	Passed	Friday, August 10, 2018
--	------------------------	--------	----------------------------

