

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20181345, Building Permit - Commercial

Address: 100 SW 3RD ST, Unit:A, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Monday, August 13, 2018

### Corrective Action Required

1	Misc	NEC 380-10; 410-56(f) / IRC E3901.10; E3902.6 SECURING OF ELECTRICAL RECEPTACLES / SWITCHES: SOME NOT SECURED SOLID TO BOX. ENSURE NONE ARE "SOFT" OR LOOSE SIDE-TO-SIDE. CHECK ALL, INCLUDING BELOW BREAK ROOM SINK.
---	------	---

### Corrective Action Required

2	Misc	IN MECHANICAL ROOM SECURE MC ELECT CABLE TO WALL
---	------	--

**Comments:**