

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20181667, Development - Subdivision
Whispering Woods

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	John DiMauro	Partial	Monday, August 13, 2018

Informational

- 1 Ron Paynter, Joe Starlin and I made two site visits AM & PM to inspect the sanitary line A. The Redford crew had 6 of the lateral's installed and the MH A-2 installed. They poured the trench checks for the service line with flowable fill. We verified the size and locations of the trench checks.

Comments: