
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20180476, Building Permit - Residential

Address: 1345 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Thursday, August 16, 2018

Informational

1 Ronald Paynter 08/16/2018 8:01 AM Driveway approach meets spec

DEI-Sidewalk Inspection	Ronald Paynter	Failed	Thursday, August 16, 2018
-------------------------	----------------	--------	---------------------------------

Informational

1 The sidewalk was formed and the ADA was formed up. Bob Burns and Matt Munger came out to assist with this inspection. This passed pre-inspection and is ready to pour. Steve Robbins 08/16/2018 7:33 AM

Corrective Action Required

2 Ronald Paynter 08/16/2018 1545 PM The ADA Ramp does not meet ADA guidelines.

Driveway Inspection	Ronald Paynter	Partial	Thursday, August 16, 2018
---------------------	----------------	---------	---------------------------------

Informational

1 The pre-pour appeared to be in good order. There was 4" of compacted rock and appeared to room for 6" of concrete. Steve Robbins 08/16/2018 7:24 AM

DEI-Sidewalk Inspection

Ronald Paynter

Partial

Thursday,
August 16,
2018

Informational

1 The sidewalk was formed and the ADA was formed up. Bob Burns and Matt Munger came out to assist with this inspection. This passed pre-inspection and is ready to pour. Steve Robbins 08/16/2018 7:33 AM

Comments:
