



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20180098	Date:	August 16, 2018
Project Title:	FOOD PANTRY BUILDING FOR ABUNDANT LIFE CHURCH	Applicant:	
Location:	1300 SW JEFFERSON ST, LEES SUMMIT, MO 64081	PROGRESSIVE ELECTRONICS INC 6102 ARLINGTON AVE RAYTOWN, MO 64133	
Type of Work:		Primary:	(816) 765-5750
Occupancy Group:	S-1		
Description:	FOOD PANTRY BUILDING FOR ABUNDANT LIFE CHURCH		
Construction Type:	Type VB (Unprotected)		
Map Page:	195P		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED: (information purposes)

Acceptance testing of the system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.