

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181676, Building Permit - Residential

Address: 4423 SW AMETHYST DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Residential</b>	Jason McRoy	Passed	Thursday, August 16, 2018

<b>All Rough Inspection - Residential</b>	Jason McRoy	Failed	Thursday, August 16, 2018
---	-------------	--------	---------------------------

### Corrective Action Required

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>• garage portal sheathing not nailed at 3"oc</li><li>• Fire stop electric at pantry</li><li>• Fire stops nw great room corner</li><li>• Protect nm wiring at steel beam in unfinished area in basement</li><li>• Replace knockout at bottom of service panel</li><li>• Fire stop at gas line to fire place</li><li>• Turn clean out to face out to room in basement</li><li>• * OK TO INSULATE*</li></ul> |
|---|------|---|

<b>Electrical Service Inspection - Residential</b>	Jason McRoy	Passed	Thursday, August 16, 2018
--	-------------	--------	---------------------------

<b>Gas Service Inspection - Residential</b>	Jason McRoy	Passed	Thursday, August 16, 2018
---	-------------	--------	---------------------------

**Comments:**

