

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181381, Building Permit - Residential

Address: 4431 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Partial	Monday, August 20, 2018

Corrective Action Required

2	Misc	<ul style="list-style-type: none">• nail off truss hold down at sw hall bath 1st fl• All clean outs missing caps in basement• Drain for kitchen is broken off
---	------	---

*OK TO INSULATE *

Comments: