

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181745, Building Permit - Residential

Address: 1713 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Residential</b>	Mike Copeland	Passed	Monday, August 20, 2018
<b>Electrical Service Inspection - Residential</b>	Mike Copeland	Passed	Monday, August 20, 2018
<b>Gas Service Inspection - Residential</b>	Mike Copeland	Passed	Monday, August 20, 2018
<b>All Rough Inspection - Residential</b>	Mike Copeland	Failed	Monday, August 20, 2018

### Corrective Action Required

1	Misc	-NAIL GARAGE PORTAL WALLS 3" O.C. PER PLANS -INSTALL SECURITY BLOCKING AT REAR DECK DOOR -HAVE ENGINEER ADDRESS CHANGE IN REAR BASEMENT WALL, WINDOW LOCATION CHANGED, INSTALLED AT WEST END WHERE EXTERIOR BRACED WALL PANELS WERE REQUIRED.
---	------	---

### Comments: