Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181329, Building Permit - Commercial Address: 1130 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Final Building John Borns Partial Wednesday, August 22, 2018

Inspection - Commercial

Corrective Action Required

1 Misc OBTAIN LSFD APPROVAL OF EXIT SIGNS WHICH PRESENTLY DO

NOT ILLUMINATE UNDER NORMAL POWER.

Partial Correction

2 Misc OK TO SET UP FOR BUSINESS. FULL APPROVAL AWAITING FIRE

DEPARTMENT APPROVAL OF EXIT SIGNS.

Comments: