

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181745, Building Permit - Residential

Address: 1713 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Partial	Thursday, August 23, 2018

Corrective Action Required

2	Misc	BASEMENT WALL, WINDOW LOCATION CHANGED, INSTALLED AT WEST END WHERE EXTERIOR BRACED WALL PANELS WERE REQUIRED. Waiting on letter from engineer. Engineer approved corrections have already been made.
---	------	---

Comments: