

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180023, Building Permit - Residential

Address: 408 SE WEISS CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Monday, August 27, 2018

Corrective Action Required

1	Misc	-FINAL GRADE, SOD, SPLASHBLOCKS -OVERGROWN WEEDS -NO EROSION CONTROL AT THE REAR OF THE PROPERTY DISCHARGING INTO THE CREEK -REAR DOOR SECURITY SCREWS
---	------	--

Comments: