

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180838, Building Permit - Residential

Address: 1841 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Jason McRoy	Failed	Wednesday, August 29, 2018

Gas Piping Inspection - Residential	Jason McRoy	Failed	Wednesday, August 29, 2018
--	-------------	--------	----------------------------

Corrective Action Required

2	Misc	* NO PRESSURE IN GASLINE * GASLINE IS NOT BONDED * FIREPLACE IN GREATROOM IS NOT SET IN PLACE OR CONNECTED TO GAS LINE
---	------	---

Comments: