

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181829, Building Permit - Residential

Address: 1325 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Passed	Wednesday, August 29, 2018

Erosion Control	Khanh Nguyen	Failed	Wednesday, August 29, 2018
------------------------	--------------	--------	----------------------------

Corrective Action Required

1	DCM2 Erosion Control	DEFICIENT EROSION CONTROL INSTALLATION.
---	----------------------	---

SHALL PROVIDE 3/4" GRAVEL AT LOT ENTRANCE.

LAST WARNING. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

Comments: