

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRSUBD20180158, Development - Subdivision  
Park Ridge 6th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Water Line - Hydrostatic Test	Steve Robbins	Passed	Thursday, August 30, 2018

Informational

- 1 John Jackson has been working out here. He issued a hydrostatic pressure test on 8/16 and 8/17 and both times they failed. Steve Robbins 08/20/2018 3:30 PM

Informational

- 2 The hydrostatic pressure test for the 8" water main has now passed. Steve Robbins 08/30/2018 9:43 AM

**Comments:**