

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20170788  
**Address:** 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064  
**Inspected On:** Thursday, August 30, 2018  
**Inspected By:** Khanh Nguyen Michael Weissenbach  
**Expiration Date:** 11/30/2018 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Temporary C of O	Thursday, August 30, 2018

**Corrective Action Required:**

1	Misc	APPROVAL REQUIRED FROM: PLANNING, FIRE, WATER, FIELD SERVICE ENGINEER -SUBMIT FINAL SPECIAL INSPECTION LETTER -GROUND ALL LIGHT POLE BASES -INSTALL BONDING JUMPER AROUND DEVICES (BACKFLOW, ETC) AT WATER SERVICE WITH SAME SIZE GROUNDING ELECTRODE CONDUCTOR -GAS TEST NOT HOLDING PRESSURE FOER THE TWO SMALLER PIPES -PAINT ROOFTOP GAS PIPING -SEAL ROOF PENETRATIONS -PROTECT GROUNDING CONNECTION TO ROD. -POST AVAILABLE FAULT CURRENT PER 110.24 AND ARC-FLASH HAZARD WARNING PER 110.16
---	------	--

**Alarm Test**

Michael  
Weissenbach

Passed

Thursday, August  
30, 2018

**Sprinkler - Flow Test**

Michael  
Weissenbach

Passed

Thursday, August  
30, 2018