

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20181667, Development - Subdivision
Whispering Woods

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	Tom Chandler	Partial	Thursday, August 30, 2018

Informational

- 1 Tom Chandler 08/30/2018 2:17 PM Removed and replaced existing MH G-1. Installed 126 L/F of 24" SDR 26 pipe. Poured invert and existing main back in service.

Comments: