

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170788, Building Permit - Commercial

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Friday, August 31, 2018

Corrective Action Required

1	Misc	APPROVAL REQUIRED FROM: PLANNING, FIRE, WATER, FIELD SERVICE ENGINEER -SUBMIT FINAL SPECIAL INSPECTION LETTER -GROUND ALL LIGHT POLE BASES -INSTALL BONDING JUMPER AROUND DEVICES (BACKFLOW, ETC) AT WATER SERVICE WITH SAME SIZE GROUNDING ELECTRODE CONDUCTOR -PAINT ROOFTOP GAS PIPING -SEAL ROOF PENETRATIONS -PROTECT GROUNDING CONNECTION TO ROD. -POST AVAILABLE FAULT CURRENT PER 110.24 AND ARC-FLASH HAZARD WARNING PER 110.16 -PROTECT THE SERVICE EQUIPMENTS
---	------	--

Comments: