
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20180158, Development - Subdivision
Park Ridge 6th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test 1	Steve Robbins	Passed	Tuesday, September 04, 2018

Informational

1 The water samples for this project have been passed. We had samples from 5 different locations and they had 2 straight days of passing tests. Steve Robbins 09/04/2018 9:42 AM

Comments:
