

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20182223, Building Permit - Commercial

Address: 425 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Passed	Tuesday, September 04, 2018
In-wall Inspection	John Borns	Passed	Tuesday, September 04, 2018
Underslab Electrical Inspection - Commercial	John Borns	Passed	Tuesday, September 04, 2018

Comments: INSTALL ONE MISSING BOCA PLATE TO PROTECT PVC PLUMBING PIPE. THEN OK TO COVER WHEN READY FRAMING AND SYSTEMS TO BE ENCLOSED AT WALLS, SOFFITS, BULKHEADS, AND GWB CEILINGS.