

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20182431, Building Permit - Residential

Address: 4426 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Mike Copeland	Failed	Wednesday, September 05, 2018

Corrective Action Required

1	Misc	-PROVIDE COMPACTION TESTS FROM ENGINEER AND VERIFICATION OF THE SOIL BEARING CAPACITY BELOW THE GRAVEL. -NO PLANS ON SITE, NO STEEL IN PLACE
---	------	---

Comments: