

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181324, Building Permit - Residential
Address: 2504 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mark Harding	Passed	Thursday, September 06, 2018
Gas Service Inspection - Residential	Mark Harding	Passed	Thursday, September 06, 2018
All Rough Inspection - Residential	Mark Harding	Failed	Thursday, September 06, 2018

Corrective Action Required

1	Misc	vent all bath fans -firestop north bsmt bedroom at i beam. -firestop dbl wall 10' horizontal (between stud walls) -left bsmt 1/2 bath at soffit and fur down.] ok to insulate
---	------	---

Comments: