Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Address: 910 NW BLUE PKWY, Unit:Y, LEES SUMMIT, MO 64086 This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.				
				Inspection:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, September 07, 2018	
Partial Correction 1 Misc	F.	UNDERSLAB DWV PIPING OK TO COVER EXCEPT PIPING FOR TWO F.D.s NEAR SOUTH WALL NOT SHOWN ON APPROVED DRAWINGS.		

Comments: