## **Development Services Department**

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRRES20181168, Building Permit - Residential Address: 1313 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Khanh Nguyen Failed Friday, September 07, 2018

Residential

Corrective Action Required

1 Misc -Install hanger for double joist connection at stair.

As an alternative, the framer can install Simpson L support

brackets on both sides of the double joist

SEPT-7-REINSPECTION FEE ASSESSED

\*\*OK TO INSULATE

**Comments:**