

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180820, Building Permit - Residential

Address: 4071 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Suspended Slab Inspection	Khanh Nguyen	Failed	Friday, September 07, 2018

Corrective Action Required

1 Misc

STRUCTURAL SLAB:

-GARAGE REBARS NOT EPOXIED INTO FOUNDATION WALL
-INSTALL 4 #4 REBAR @ 6" OC EACH WAY OVER THE PIER PER PLAN

Underslab Plumbing Inspection - Residential	Khanh Nguyen	Passed	Friday, September 07, 2018
--	--------------	--------	----------------------------

Comments: