

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181397, Building Permit - Residential

Address: 1717 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, September 10, 2018

Corrective Action Required

1 Misc

FRAMING:

-Complete framing at fireplace

**Nail the fireplace to the framing

-Security blocking for deck and basement door

-Min 5 stud support for I beam at kitchen wall

**Close gap between studs and nail together with 16d @24" (or equivalent nailing)

-Solidblock joist ends above basement I beam

-Support joist located above opening to space under stoop

**OK TO INSULATE

Comments: