

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20174064, Public Works Infrastructure Permit - Commercial  
COLEMAN EQUIPMENT

Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sidewalk Inspection	Steve Robbins	Passed	Tuesday, September 11, 2018

Informational

- 1 Inspected the last section of sidewalk to the fire hydrant. There was about 200 ft. The rock was installed and compacted. Steve Robbins 08/01/2018 4:10 PM

Informational

- 2 All the sidewalk in front of the building and going across the approach which has an ADA appear to be compliant with city standards. This completes all the sidewalk for this project that is public. Steve Robbins 09/11/2018 7:10 AM

Comments: