

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20161917, Building Permit - Residential

Address: 408 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

**Final Mechanical
Inspection - Residential**

John Borns

CLOSED WITH COMMENT Tuesday, September 11, 2018

**Comments: NO ISSUES FOUND WITH INSTALLATION OF AC CONDENSER. MAX A/C BREAKER
AMPERAGE 25A. NO ANSWER AT DOOR. ACCESS TO INTERIOR NOT PROVIDED. CLOSE PERMIT.**