

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172441, Building Permit - Residential

Address: 4721 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Thursday, September 13, 2018

Corrective Action Required

1	Misc	-Cover missing at rear outdoor receptacle -Seal above AC disconnect and at gas pipe wall penetration -Breaker lock for oven, hood -Deck receptacle cover not installed properly and fell off -Screw in the embedded brace of the basement exterior door to studs with min 3" screws
---	------	---

Comments: