

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20181521, Building Permit - Commercial

Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086699 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Failed	Thursday, September 13, 2018

### Corrective Action Required

1	Misc	ICC A117.1 SECTION 604.6: WATER CLOSET FLUSH VALVE HANDLE MUST BE AT FREE SIDE OF TANK
---	------	---

### Corrective Action Required

2	Misc	RESOLVE FIRE DEPT ISSUES
---	------	--------------------------

### Comments: