## **Development Services Department**

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

## Permit #:PRRES20180570, Building Permit - Residential Address: 1621 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Thursday, September 13, 2018	
Corrective Action Requir	ed			
1 Misc	• • • surfac	Label smokes Hvac heat flue with Hot water heater flu	missing outlet cover left of fire place Label smokes Hvac heat flue within 6″ of combustible surface Hot water heater flue within 6 " of combustible	
	•	Final grade Sod Smoke alarm in util Cover for attic acce	ity room should be a combo ss in laundry rm nt light fixture in laundry rm	

## **Comments:**