

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20174064, Public Works Infrastructure Permit - Commercial

COLEMAN EQUIPMENT

Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Construction Inspection	Steve Robbins	Passed	Friday, September 14, 2018

Informational

- 1 The servicer water line has been insalled, the water dept. did a tap and brought the meter out and the contractor installed the line. This has all been completed.

DEI-Stabilized Subgrade	Steve Robbins	Passed	Friday, September 14, 2018
-------------------------	---------------	--------	----------------------------------

Informational

- 1 The contractors used portland cement for the subgrade, they tilled it in with a tiller and used a water tiller. This is on the main road that is coming off of Lakewood way. The road is considered private. I spoke with Dan and we allowed them to not put in MO-type 5. They installed the curbs and the base asphalt on portland with no rock.

Comments: