

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20182998, Building Permit - Residential

Address: 1751 NE WOODLAND SHORES DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Residential	Khanh Nguyen	Passed	Friday, September 14, 2018

Comments:

CONTRACTOR REQUESTED UNDERGROUND ELECTRICAL TRENCH FROM METER LOCATION (SERVICE NOT YET INSTALLED) TO KCPL PEDESTAL. TRENCH > 24" DEPTH