

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20182155, Building Permit - Residential

Address: 3603 SW CRANE RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Jason McRoy	Partial	Monday, September 17, 2018

Corrective Action Required

1	Misc	* steel in pool deck only bonded.
---	------	-----------------------------------

Comments: