



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20182297	Date:	September 17, 2018
Project Title:	NOTHING BUNDT CAKES	Applicant:	
Location:			
	910 NW BLUE PKWY, Unit:Y, LEES	KANSAS CITY FIRE AND SECURITY LLC	
	SUMMIT, MO 64086	901 E LOULA ST	
Type of Work:		OLATHE, KS 66061	
Occupancy Group:	B		
Description:	TENANT FINISH FOR CARRY OUT	Primary: (913) 780-5237	
	BAKERY		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Acceptance testing of the devices installed will be required prior to the tenants final occupancy inspection. Contact the fire department to schedule testing.(816)969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.