

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161942, Building Permit - Commercial

Address: 819 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Passed	Tuesday, September 18, 2018
Final Building Inspection - Commercial	John Borns	Passed	Tuesday, September 18, 2018
All Rough Inspection - Commercial	John Borns	Passed	Tuesday, September 18, 2018

Comments: NO ISSUES FOUND ON FINAL INSPECTION. CLOSE PERMIT.