

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20182998, Building Permit - Residential

Address: 1751 NE WOODLAND SHORES DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Khanh Nguyen	Failed	Tuesday, September 18, 2018

Corrective Action Required

1	Misc	-LABEL ALL BREAKER -CLOSE HOLE AT BOTTOM OF THE DISCONNECT -EXPOSE HEAD OF THE GROUNDING CONNECTION -PROTECT THE EXPOSED UF CABLES. CODE REQUIRES 18" UNDERGROUND PROTECTION; OR MIN. 2" CONCRETE PROTECTION
---	------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: