

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20182297, Building Permit - Commercial

Address: 910 NW BLUE PKWY, Unit:Y, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Tuesday, September 18, 2018

Corrective Action Required

3	Misc	PLUMBING SPECIFICATION REQUIRES TYPE "L" COPPER TUBING FOR H & C WATER
---	------	--

Corrective Action Required

4	Misc	OVEN IS OBSTRUCTING WALL COVERINGS
---	------	------------------------------------

Comments: