

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20181505, Building Permit - Commercial

Address: 1040 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Tuesday, September 18, 2018

### Corrective Action Required

1 Misc

**\*\*SERVICE UPGRADE OF THE MAIN BUILDING TO 200 AMP  
SERVICE**

**-RACEWAY AND ENCLOSURE ENCLOSING THE SERVICE  
CONDUCTORS SHALL BE BONDED PER NEC 250.92(B)  
-ONLY ONE CONDUCTOR IS ALLOWED FOR EACH LUG  
-BURY THE ROD GROUNDING CONNECTION**

### Comments: