

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180698, Building Permit - Commercial

Address: 209 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Mark Harding	Partial	Tuesday, September 18, 2018

Corrective Action Required

1	Misc	PARTIAL- INTERIOR CENTER FOOTING
---	------	-------------------------------------

Comments: