



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20172500	Date:	September 19, 2018
Project Title:	MERIDIAN AT VIEW HIGH - CLUBHOUSE	Applicant:	
Location:		RANGER FIRE INC	
	201 NW KESSLER DR, LEES SUMMIT, MO 64081	1000 S MAIN ST STE 150	
Type of Work:		GRAPEVINE, TX 76051	
Occupancy Group:	A-3	Primary: (817) 410-9070	
Description:	NEW CLUBHOUSE WITH DOG GROOMING AND GYM		
	FOUNDATION PERMIT - PRCOM20180696		
Construction Type:	Type VB (Unprotected)		
Map Page:	194F		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Rejected

Include a floor plan and engineered sprinkler design for the Clubhouse.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.