



## FIRE DEPARTMENT

### PLAN REVIEW CONDITIONS

September 20, 2018

BNB DESIGNS ARCHITECTURE AND INTERIORS  
108 N NETTLETON AVE  
BONNER SPRINGS, KS 66012

Permit No: PRCOM20183019  
Project Title: MK16 ENTERPRISES, LLC  
Project Address: 419 SW WARD RD, LEES SUMMIT, MO 64081  
Parcel Number: 61420042900000000  
Location: WESTSIDE PLAZA LOTS 1A, 1B, 2A & 2B & TRS A & B---LOT 1A  
Type of Work: CHANGE OF TENANT  
Occupancy Group: MERCANTILE  
Description: TENANT FINISH FOR RETAIL SALES OF HEALTH PRODUCTS

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

#### **Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

Address shall be readable from the roadway

2. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide a minimum of one 2A-10BC fire extinguisher

Fire extinguisher to be mounted on a wall close to an exit.

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved with Conditions**

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***