

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173335, Building Permit - Residential

Address: 1709 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, September 21, 2018

Corrective Action Required

1	Misc	-Exterior hose bibb missing handle -Deck: the lag screws must go through the spacer -Pendant light not allowed within bathtub zone -Install a receptacle within 3 ft of the master bath sink -Restore power and battery for smoke alarm -Clear gfci fault at kitchen countertop. Keeps tripping -Anti hammer arrestor for dish washer clothes washer -40 amp rated circuit required for the cooktop rated over 8.75 kw
---	------	---

Comments: